



UK Declaration of Conformity

For the following equipment:

Product Name: Switching Power Supply

Model Designation: HEP-600-x (x=12,15,20,24,30,36,42,48,54); HEP-600C-w (w=12,24 or 48)

The designated product(s) is(are) in conformity with the relevant legislation:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012: SI 2012 No. 3032

Electrical Equipment (Safety) Regulations 2016:

BS EN 62368-1:2014+A11 TUV certificate No: R50448651

Electrical Compatibility Regulations 2016:

EMI (Electro-Magnetic Interference) Conducted emission / Radiated emission

| BS EN55032:2015+A11:2020 | Class B |
|--------------------------|---------|
| | |

Harmonic current BS EN IEC 61000-3-2:2019

Voltage flicker BS EN 61000-3-3:2013+A1:2019

EMS (Electro-Magnetic Susceptibility)

| ESD air | BS EN 61000-4-2:2009 | Level 3 | 8KV |
|---------------------------|----------------------------|---|----------------|
| ESD contact | BS EN 61000-4-2:2009 | Level 2 | 4KV |
| RF field susceptibility | BS EN 61000-4-3: 2006+A1:2 | 008+A2:2010 Level 3 | 10V/m |
| EFT bursts | BS EN 61000-4-4:2012 | Level 3 | 2KV/5KHz |
| Surge susceptibility | BS EN 61000-4-5:2014+A1:20 |)17 Level 4 | 2KV/Line-Line |
| Surge susceptibility | BS EN 61000-4-5:2014+A1:20 |)17 Level 4 | 4KV/Line-Earth |
| Conducted susceptibility | BS EN 61000-4-6:2014 | Level 3 | 10V |
| Magnetic field immunity | BS EN 61000-4-8:2010 | Level 4 | 30A/m |
| Voltage dip, interruption | BS EN IEC 61000-4-11:2020 | <5% residual voltage for 0.5 cycles, cycles, <5% residual voltage for 250 | o o |

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Regulations on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number TC1xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D:

(Name / Position)

Alex Tsai/ Director, Product Strategy Center:

(Name / Position)

Taiwan

Jun. 24th, 2021 (Date)

(Place)